

EU - DECLARATION OF CONFORMITY **14**

We,

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868

declare under our sole responsibility that our Series 605 Magnehelic® Differential Pressure Indicating Transmitter to which this declaration relates are in conformity with the following Directives and harmonized standards:

Directive 2011/65/EU Restriction of Certain Hazardous Substances in Electrical and Electronic Equipment

Directive 2014/30/EU Electromagnetic Compatibility (EMC)

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements

IEC 61000-4-2:2008 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3:2006+A1:2007+A2:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4:2012 Electromagnetic Compatibility (EMC) - Part 4-4: Testing and Measurement Techniques - Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-5:2005 Electromagnetic Compatibility (EMC) - Part 4-5: Testing and Measurement Techniques – Surge Immunity Test

IEC 61000-4-6:2013 Electromagnetic Compatibility (EMC) - Part 4-6: Testing and Measurement Techniques - Immunity to Conducted Disturbances, Induced By Radio-Frequency Fields

EN 55011:2009+A1:2010 Industrial, Scientific, and Medical (ISM) Radio Frequency Equipment – Electromagnetic Disturbance Characteristics – Limits and Methods of Measurement

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16 The Wye Estate, London Road
High Wycombe, HP11 1LH-U.K.
+44 (0) 1494 461707

On behalf of Dwyer Instruments, Inc.,



Doug McCall
Authorized Signatory
Senior Regulatory Engineer
Title of Authorized Signatory
September 25, 2018
Date of Signature

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868