



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment: **See pg 2**

System Description – Model Designations **See pg 2**

Approval Guide Listing: Category:

Ignitable / Flammable Liquid Equipment Liquid Level-Limit Switches

Dwyer Instruments Inc
102 Indiana Hwy 212
Mercoïd Div
PO Box 373
Michigan City
IN
46361-0373
United States

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
3510	January 2000		

Original Approval Job Identification: 1D9A0AE Approval Granted: 1992

Related Report: 1D3A2AF

Subsequent Revisions:

To verify the availability of the Approved product, please refer to www.approvalguide.com


J. E. Marquedant
Manager of Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

Date 9 February 2017



Member of the FM Global Group



Certificate of Compliance

Flotect Model L4 Float Switch

Flotect® Model L4 Float Switch, Explosionproof for Class I, Division 1, Groups C and D; Dust-Ignition for Class II, Division 1, Groups E, F and G Hazardous (classified) Locations; Indoor/Outdoor (NEMA Type 4, IP56).

The model no. configuration for the float switch is L4 -X-Y-Z where the letters describe the product as follows:

X = Indicates the switch body type, either -SS (stainless steel option) or blank (standard brass construction).

Y = Indicates the mounting style, either -TOP (top mount option) or blank (standard side mount).

Z = Indicates switch type, either -D (DPDT switch option) or blank (standard SPDT switch).



Member of the FM Global Group