



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

ULT-ab-cd. UltraSonic Level Transmitters

XP/I/BCD/T6 Ta=60°C; DIP/II,III/1/EFG/ T6 Ta=60°C; Type 4X

a = Range: 1 (24.6 ft/7.5m) or 2 (32.8 ft/10m)

b = Process Connection: 1 (NPT) or 2 (BSPT)

c = M2 Conduit Connection or blank.

d = C5 or blank.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; and dust-ignitionproof for Class II/III, Division 1, Groups E, F and G hazardous (classified) locations; indoor/outdoor (Type 4X).

FM Approved for:

Dwyer Instruments Inc.
Michigan City, Indiana, USA



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3810	2005
ANSI/NEMA 250	2003

Original Project ID: 3034268

Approval Granted: April 29, 2009

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3056943	December 16, 2015		

FM Approvals LLC

J.E. Marquedant
Manager, Electrical Systems

16 December 2015
Date