



12

EC - DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.
P.O. Box 373
Michigan City, IN 46361, USA
(219) 879-8868

declare under our sole responsibility that our Models SCT10-102, SCT20-103, SCT10-100, SCT-RLY12 and SCT-RLY24 to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

EN 61326-1 (2006) Electrical Equipment for Measurement, Control, and Laboratory Use - EMC Requirements -Part 1: General Requirements

IEC 61000-4-2 (2001) Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3 (2002) Electromagnetic Compatibility (EMC) - Part 4-3 Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4 (2004) Part 4-4 Testing and Measurement Techniques – Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-6 (2003) Part 4-6 Testing and Measurement Techniques – Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields

IEC 61000-4-8 (2001) Part 4-8 Testing and Measurement Techniques – Power Frequency Magnetic Field Immunity Test (Models SCT10-102, SCT20-103 and SCT10-100 only.)

Directive 2006/95/EC (Low Voltage Directive)

Models SCT10-102, SCT20-103, SCT10-100, SCT-RLY12 and SCT-RLY24

IEC 61010-1:2001 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use Part 1

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Senior Regulatory Engineer

Michigan City, Indiana, USA
2/3/12